

Teknos Oy
 P.o.Box.107
 00371 Helsinki

The following coating system for steel constructions has been tested by VTT (Technical research centre of Finland) according to the following instructions and standards:

- STUK-YTO-TR 210: 2004. *Requirements for coatings of nuclear power plant containments.*
- ASTM D 3911 - 95, 1995. *Standard test method for evaluating coatings used in light-water nuclear power plants at simulated design basis accident (DBA) conditions.*
- ASTM D 4082 - 95, 1995. *Standard test method for effects of gamma radiation on coatings for use in light-water nuclear power plants. **
- ISO 8690, 1988. *Decontamination of radioactively contaminated surfaces - Method of testing and assessing the ease of decontamination.*

Coating system	INERTA 270 A,	2 x 150 µm
	<i>Total DFT</i>	<i>300 µm</i>
Manufacturer	Teknos Oy	


According to test results, this coating system fulfils the requirements given in 2004 by Radiation and Nuclear Safety authority of Finland (STUK) for Radiation (gamma) and DBA-resistance and Ease of decontamination. Full experimental details have been given in report VTT-R-03683-16.

**) The total accumulated dose was 1×10^8 rads (= 1×10^6 J/kg = 1×10^6 Gy) and the dose rates were greater than the regulator required.*

Espoo, 07.12.2020

DocuSigned by:

7CB4882A118A42C...
 Pasi Väisänen
 Engineer

DocuSigned by:

4419E54C702A444...
 Sami Penttilä
 Research Team Leader